Law (Edn) (1930), **Department.**

MS SERIES.

G.O. No. 191

DATED 23/9/93

[Despatch Abstract.]

Grant - Building - St. Aloysius College, Mangalore - Construction of vernacular class rooms - List of approved works - Included.

St.Aloysius College, M a n g a l o r e - Vernacular class rooms



ENCLOSURES.
No.
Spare copies

R.C. No. 229 D/29

Station I r a *Dated the* 30- 0- 30 19

From (Name) W.E.Smith Esq., M.A.,
(Designation) Ag.Director of Public Instruction
M a d r a s.

To The Secretary to the Government of Madras.
Law(Education Department

Sir,

I have the honour to address Government recommending a grant towards the cost of constructing a block of building for the St.Aloysius College, Mangalore.

The existing accommodation for the College Department is insufficient and in consequence, different classes are being held in one and the same room thus causing much inconvenience to the lecturers and to the students. It is therefore proposed to construct a new block of building consisting of 3 rooms which are to be utilised for conducting Vernacular classes.

The plans and estimates for the work are herewith enclosed. They were scrutinised by the

the Consulting Architect and were revised in the light of his remarks. The estimates as revised by the Consulting Architect stand at Rs.9420 (vide his remarks dated 30- 7- 30 copy enclosed) and the Correspondent has also agreed to carry out the suggestions made by the Consulting Architect.

I therefore recommend that Government may be pleased to place the scheme in the list of approved works at a cost of Rs.9420 so as to render it eligible for a grant not exceeding Rs.4760 if and when funds become available, provided the conditions of the Grant-in-Aid Code are duly fulfilled.

I may also add that I have given the management permission to proceed with the work without prejudice to the question of grant, as the correspondent recently represented to me that was the proper season for digging foundations and requested early sanction for the scheme.

I have the honour to be,

S i r,

Your most obedient servant,

for Director of Public Instruction

Copy of letter dated 30th July 1930 from the Consulting Architect to Government.

St.Aloysius College,Mangalore- Construction of additional block of three rooms. Estimate Rs.9,400/-

The estimate has been revised as instructed by this office.

The pressure on the foundations comes to 0.90/per sq.ft. on the end wall,0.95 ton per sq.ft on the cross wall and 0.92 ton per sq.ft on the wall adjoining the verandah; and these are safe for gravelly soil.

Save stress on 'Paduva' quarry laterite of Mangalore is 3½ tons per Sq.ft. As the maximum pressure on the pier works to 2.30 tons. it may be considered safe provided the Paduva laterite is used, if not, these piers will have to be built in cement as the safe stress for other West Coast laterite is only 2 tons.

Only three trusses are provided in the estimate and hence the central span for purlins and ridge piece would be 12' and not 9'

The following roof timbers require alterations:

Principal rafter	4" x 7"	against	4" x 6"
Ridge piece	3" x 8" (fished)	"	2½" x 8"
Bressummer should be (fished)	4" x 5"	"	4" x 7"
Verandah rafters at 2' -9" centres	2" x 6"	"	2" x 5"

The corrections have been carried out and the estimate altered.

Rates:- Data for the rate allowed for ventilator may be passed.

From the sketch given in the Correspondent's letter, page 53, it is seen that the proposed building site would be about 23' below the level of the road by the side

The Correspondent should see that proper arrangements are made for suitable drainage of site.

The estimate as now altered in this office for Rs.9,420/- may be recommended for acceptance.

Law Education Department

Grant

Building St. Xaviers College, Mangalore

List of approved works - Included

for clinic

Read the following paper:

ORDER: No

The Government sanction the inclusion, ~~xxx~~ in the ~~xx~~ list of approved works maintained in pursuance of G.O. No. 5128 Law (Education, dated the 10th May 1922.

~~No. 4 Law (Education), dated 17th June 1922.~~

as building for hostel

at an estimated cost of Rs. 9,420/- While this approval does not convey any guarantee of grant, it will render the work eligible for a grant under the provisions of the ~~Code of Regulations for European~~ Grant-in-Aid-Code, one half of the Contingent expenditure Rs. 710/-

if and when funds become available, provided that all the conditions prescribed in the Code are duly complied with.